

Number	KIP-16166/E	Replaces	KIP-16108/E
Issued	04-02-2019	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	2001325/7	Page	1 of 5
PIN	0476CR1325		

EC TYPE EXAMINATION CERTIFICATE

Kiwa Cermet Italia, notified body for council Directive 92/42/EEC, hereby declares that according to article 4 of commission regulation (EU) No. 813/2013 the products

Central heating condensing boilers

Trade mark: **SAVIO**

Models: *as specified in the **Annexes 1, 2, 3 and 4***

Placed on the market by **BSG Caldaie a Gas S.p.A.**
Via Pravolton, 1/b
33170 Pordenone (PN), Italy

Have achieved the following (see Annexes 1, 2, 3 and 4) full and part load efficiencies.

The assessment test have been performed using the following standards as guidelines:

EN 15502-1:2012+A1:2015
EN 15502-2-1:2012+A1:2016

The validity of this certificate can be verified on request at the following e-mail address: info@kiwa.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and /or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it


www.kiwa.it
www.kiwacermet.it

GASTEC

Chief Operating Officer
Giampiero Belcredi




PRD N° 069B



Organismo Notificato n. 0476

Rev.9



Number	KIP-16166/E	Replaces	KIP-16108/E
Issued	04-02-2019	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	2001325/7	Page	2 of 5
PIN	0476CR1325		

EC TYPE EXAMINATION CERTIFICATE


ANNEX 1

Models:

	M260MK.2025 SM/..., M262MK.2025 SB/...	M260MR.2025 SM/...	M260MK.2025 SV/...
η_{100}	96,7 %	96,5 %	96,7 %
η_{30}	108,0 %	107,4 %	108,0 %
η_4	87,1 %	86,9 %	87,1 %
η_1	97,2 %	96,7 %	97,2 %
P ₄	19,3 kW	19,3 kW	19,3 kW
P ₁	6,5 kW	6,5 kW	6,5 kW
C.Heater?	Yes	Yes	No ⁽¹⁾
B ₁ Boiler?	No	No	No
Type of boiler:	"Condensing"	"Condensing"	"Condensing"

	M260MR.2025 SV/...	M260MK.2530 SM/..., M262MK.2530 SB/...	M260MR.2530 SM/...
η_{100}	96,5 %	97,0 %	96,8 %
η_{30}	107,4 %	107,6 %	107,1 %
η_4	86,9 %	87,3 %	87,2 %
η_1	96,7 %	96,9 %	96,4 %
P ₄	19,3 kW	24,2 kW	24,2 kW
P ₁	6,5 kW	8,1 kW	8,1 kW
C.Heater?	No ⁽¹⁾	Yes	Yes
B ₁ Boiler?	No	No	No
Type of boiler:	"Condensing"	"Condensing"	"Condensing"

	M260MK.2530 SV/...	M260MR.2530 SV/...	M260MK.20 SR/...
η_{100}	97,0 %	96,8 %	96,7 %
η_{30}	107,6 %	107,1 %	108,0 %
η_4	87,3 %	87,2 %	87,1 %
η_1	96,9 %	96,4 %	97,2 %
P ₄	24,2 kW	24,2 kW	19,3 kW
P ₁	8,1 kW	8,1 kW	6,5 kW
C.Heater?	No ⁽¹⁾	No ⁽¹⁾	No
B ₁ Boiler?	No	No	No
Type of boiler:	"Condensing"	"Condensing"	"Condensing"



Number	KIP-16166/E	Replaces	KIP-16108/E
Issued	04-02-2019	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	2001325/7	Page	3 of 5
PIN	0476CR1325		

EC TYPE EXAMINATION CERTIFICATE

ANNEX 2

Models:

	M260MR.20 SR/...	M260MK.25 SR/...	M260MR.25 SR/...
η_{100}	96,5 %	97,0 %	96,8 %
η_{30}	107,4 %	107,6 %	107,1 %
η_4	86,9 %	87,3 %	87,2 %
η_1	96,7 %	96,9 %	96,4 %
P_4	19,3 kW	24,2 kW	24,2 kW
P_1	6,5 kW	8,1 kW	8,1 kW
C.Heater?	No	No	No
B ₁ Boiler?	No	No	No
Type of boiler:	"Condensing"	"Condensing"	"Condensing"

	M260V.1616 SV/...	M260V.16 SR/... M260V.16 OV/...	M260V.2025 SM/..., M261V.2025 SM/..., M263V.2025 SM/...
η_{100}	96,9 %	96,9 %	96,6 %
η_{30}	107,6 %	107,6 %	107,6 %
η_4	87,3 %	87,3 %	87,0 %
η_1	96,9 %	96,9 %	96,9 %
P_4	16,5 kW	16,5 kW	20,3 kW
P_1	5,5 kW	5,5 kW	6,8 kW
C.Heater?	No ⁽¹⁾	No	Yes
B ₁ Boiler?	No	No	No
Type of boiler:	"Condensing"	"Condensing"	"Condensing"

	M260V.2025 SV/...	M260V.20 SR/... M260V.20 OV/...	M260V.2530 SM/...
η_{100}	96,6 %	96,6 %	97,4 %
η_{30}	107,6 %	107,6 %	107,4 %
η_4	87,0 %	87,0 %	87,7 %
η_1	96,9 %	96,9 %	96,7 %
P_4	20,3 kW	20,3 kW	24,4 kW
P_1	6,8 kW	6,8 kW	8,1 kW
C.Heater?	No ⁽¹⁾	No	Yes
B ₁ Boiler?	No	No	No
Type of boiler:	"Condensing"	"Condensing"	"Condensing"

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadrano, 23
40057 Granarolo dell'Emilia (BO)


Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it
www.kiwacermet.it

GASTEC



Number KIP-16166/E Replaces KIP-16108/E
Issued 04-02-2019 Scope Directive 92/42/EEC
Regulation (EU) No. 813/2013
Report 2001325/7 Page 4 of 5
PIN 0476CR1325

EC TYPE EXAMINATION CERTIFICATE

ANNEX 3

Models:

	M260V.2530 SV/...	M260V.25 SR/... M260V.25 OV/...	M260V.3035 SM/..., M261V.3035 SM/..., M263V.3035 SM/...
η_{100}	97,4 %	97,4 %	97,4 %
η_{30}	107,4 %	107,4 %	107,4 %
η_4	87,7 %	87,7 %	87,7 %
η_1	96,7 %	96,7 %	96,7 %
P ₄	24,4 kW	24,4 kW	28,2 kW
P ₁	8,1 kW	8,1 kW	9,3 kW
C.Heater?	No ⁽¹⁾	No	Yes
B ₁ Boiler?	No	No	No
Type of boiler:	"Condensing"	"Condensing"	"Condensing"

	M260V.3035 SV/...	M260V.30 SR/...
η_{100}	97,4 %	97,4 %
η_{30}	107,4 %	107,4 %
η_4	87,7 %	87,7 %
η_1	96,7 %	96,7 %
P ₄	28,2 kW	28,2 kW
P ₁	9,3 kW	9,3 kW
C.Heater?	No ⁽¹⁾	No
B ₁ Boiler?	No	No
Type of boiler:	"Condensing"	"Condensing"

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadrano, 23
40057 Granarolo dell'Emilia (BO)


Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755
Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it
www.kiwacermet.it

GASTEC



Number	KIP-16166/E	Replaces	KIP-16108/E
Issued	04-02-2019	Scope	Directive 92/42/EEC Regulation (EU) No. 813/2013
Report	2001325/7	Page	5 of 5
PIN	0476CR1325		

EC TYPE EXAMINATION CERTIFICATE

ANNEX 4

Note:

η_{100} = At rated heat output and high-temperature regime - NCV (*)

η_{30} = At 30 % of rated heat output and low-temperature regime - NCV (**)

η_4 = At rated heat output and high-temperature regime - GCV (*)

η_1 = At 30 % of rated heat output and low-temperature regime - GCV (**)

P_4 = At rated heat output and high-temperature regime (*)

P_1 = At 30 % of rated heat output and low-temperature regime (**)

C.Heater = Combination heater (Yes = with domestic hot water production / No = Heating system only)

B₁ Boiler = B₁ according CEN/TR 1749:2014

Type of boiler = "Condensing Boiler" or "Low Temperature Boiler" or Other Boiler"

Efficiency's values have been measured with gas G20.

⁽¹⁾ The boiler can be connected to an external tank for the domestic hot water production

(n.t. = not tested)

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadrano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC